



SECTION A-A

NOTES

1. Final 28 day concrete strength to be 5000 psi.
2. A 3/4 inch coil loop insert (Dayton F63) with an insert locator plug (Dayton T21) for lifting the pad at the center of gravity with a swivel plate.
3. Manufacturer's identification and month/year when manufactured shall be legibly marked in/on concrete in the top near the center.
4. Concrete and concrete design shall be in accordance with ACI 318-1986.

ORIGINAL 4/23/70	PAD – PRECAST CONCRETE – TRANSFORMER 167 KVA MAXIMUM – 42" X 48" X 4"		
APPROVED 8/1/91 Festivus	NORTHEAST UTILITIES MATERIAL SPECIFICATION SPC P-009 11		