






PLAN VIEW



ELEVATION





**INSERT w/CLEANOUT
DETAIL
(N.T.S.)**

GENERAL NOTES:

1. DESIGN CONFORMS TO CDOT AND LOCAL SPECIFICATIONS.
2. CONCRETE COMPRESSIVE STRENGTH: 4,000 PSI @ 28 DAYS.
3. REINFORCING STEEL DEFORMED BARS CONFORM TO LATEST ASTM SPECIFICATION A615.
4. ALL REINFORCING SHALL HAVE 1 1/2" MIN. CONCRETE COVER.
5. METHOD OF MANUFACTURE: WET CAST.
6. STRUCTURE SHALL BE CAST USING A SELF COMPACTING CONCRETE MIX.
7. SECTION IS MONOLITHIC.

APPROXIMATE WEIGHT: 550 LBS.


UNITED CONCRETE PRODUCTS, Inc		CONCRETE HANDHOLE - TYPE III		UCP JOB NUMBER	
173 CHURCH STREET YALESVILLE, CT 06492 TEL: (203)-289-3119 FAX: (203)-265-4941		CUSTOMER		SCALE 3/4" = 1'-0"	
JOB		LOCATION		DATE	
DRAW		CHK		SHEET	
HH-3					



NOTE: GALVANIZE COMPLETE
COVER ASSEMBLY AFTER WELDING.

APPROXIMATE WEIGHT: 35 LBS.



UNITED CONCRETE PRODUCTS, Inc		RECESSED TYPE COVER FOR TYPE III HANDHOLE		UCP JOB NUMBER	
173 CHURCH STREET YALESVILLE, CT 06492 TEL: (203)-269-3119 FAX: (203)-265-4941		CUSTOMER		SCALE 3/4" = 1'-0" U.M.O.	
JOB		LOCATION		DATE	
				DRW	
				CHK	
				SHEET RC-3	



NOTE: GALVANIZE COMPLETE COVER ASSEMBLY AFTER WELDING.

APPROXIMATE WEIGHT:

70 LBS.



UNITED CONCRETE PRODUCTS, Inc		OVERLAP TYPE COVER FOR TYPE III HANDHOLE		UCP JOB NUMBER	
173 CHURCH STREET YALESVILLE, CT 06492 TEL: (203)-289-3119 FAX: (203)-265-4941		CUSTOMER		SCALE 3/4" = 1'-0" U.N.O.	
JOB		LOCATION		DATE	
DRW		CHK		SHEET	
OC-3					